ADDENDUM NO. 2

EASTWOOD DRAIN PUMP STATION AND OPEN CHANNEL SAGINAW COUNTY, MICHIGAN

TO: ALL PROSPECTIVE BIDDERS ON THE SUBJECT PROJECT

RE: CHANGES TO BIDDING DOCUMENTS

Acknowledge Receipt of this Addendum on Page C-410-1 of the Bidform (Proposal) where indicated.

The following is a list of changes to the bidding documents:

- 1. Addendum No. 2 has been posted to the owner's website on Thursday, May 4, 2023.
- 2. All corrugated metal pipe shall be Type II Aluminized.
- 3. Division II Open Channel Bid Form Crossing numbers on bid form were labeled incorrectly. Bid items should be titled as listed below. All other information shown on bid form for each of these items is correct. A new bid form will not be issued.
 - Bid Items #27 & #57 Crossing **No. 8** Station 0+46 Section 32 Farms LLC Gravel Drive
 - Bid Items #28 & #58 Crossing **No. 9** Station 24+41 Section 32 Farms LLC Gravel Drive
 - Bid Items #33 & #34 Crossing **No. 10** Station 0+31 W Curtis Road Gravel Road
- 4. Division II Open Channel Planset Sheet 10 Length of proposed culvert for Crossing No. 10 Station 0+31 W Curtis Road shall be 70 linear feet as stated on the bid form (Item #33).

Note all clarifications and changes contained within this Addendum and/or the Pre-Bid meeting minutes supersede any data that may be contained in the plans and specifications regarding the same matter.

An unsigned acknowledgement or lack of acknowledgement shall be cause to have the bid rejected. Acknowledgment of the Addendum No. 2 by the bidder shall indicate full understanding and acceptance of this addendum in its entirety.

Please sign the Acknowledgment below and attach this Addendum No. 2 to the front of your bidding document. Acknowledge the same in the Bid Form (Proposal).

Included with the sealed bid should be:

- A. The Bid Form with Addendum No. 2 acknowledged
- B. A copy of this Addendum with the Acknowledgement Form completed

Prepared by:

SPICER GROUP, INC.

be D. OB

Luke D. O'Brien, P.E.

Project Manager

ACKNOWLEDGMENT

BIDDER:			
BY:			
DATE:			